

# 78523 - GE HID Distributor Replacement Kit Magnetic Core & Coil Ballast

### GEM400TRIAC4-5

- Magnetic ballast construction ideal for a wide variety of lighting applications.
- Precision-wound coils, ensuring even heat dissipation and the highest electrical integrity.
- Distributor replacement kit contains the appropriate core & coil with color coded leads, a properly rated capacitor and ignitor (if required) and all other components required for ballast replacement
- Tri-Tap ballast (120, 277, 347)

## **Product Photo**



#### **GENERAL CHARACTERISTICS**

200 °C Ambient Temp [Max] **Ballast Factor** Normal Core and Coil **Ballast Type** Capacitor Temp Rating 105 °C Case Temperature (Max) 105 °C Circuit Type **CWA** Insulation Class 200C Line Voltage Regulation (+/-) 10% Classification (Regulations) cUL Listed

Type Replacement kit
Type of Capacitor Oil filled

Product Technology High Intensity Discharge

### PRODUCT INFORMATION

Product Code 78523

Description GEM400TRIAC4-5

Alternative Unit Of Measure EACH Standard Package Quantity 3

Ean UPC 043168785235 Standard Package GTIN 00043168785235

No Of Items Per Sales Unit 1
No Of Items Per Standard Package 3
Sales Unit Each

UCC 043168785235

Alternative Unit Of Measure CASE

Standard Package Quantity

Ean UPC 043168785235 Standard Package GTIN 0043168785232

No Of Items Per Sales Unit No Of Items Per Standard Package

Sales Unit Case

UCC 043168785235

### **DIMENSIONS**

Diameter 2.0 Weight 11.11 lb

Exit Type


### **ELECTRICAL CHARACTERISTICS**


Capacitance 24
Supply Current Frequency<Min> 60
Voltage<Min> 450 V


### **SAFETY & PERFORMANCE**

cUL\_Listed
UL\_Listed

SPECIFICATIONS BY LAMP & WATTAGE										
Lamp	# of Lamps	Line Volts	System Watts	Nom. Line Current	System Ballast Factor	Ballast Efficacy Factor	Power Factor% (>=)	Crest Factor (<=)	THD% (<=)	Min. Starting Temp (F/C)
M59	1	120	460	4.0	1.0		90.0			-20
M59	1	277	460	1.75	1.0		90.0			-20
M59	1	347	460	1.38	1.0		90.0			-20







Feb 13, 2018 1:26:03 PM For additional information, visit www.gelighting.com